

Beleura Private Hospital

Development Update # 9, 19th December 2011

MEDICAL GASES SHUTDOWN

Supply of Medical Gases throughout Beleura will be **interrupted on 8th January 2012**.

These works are required to connect to the existing mains for future upgrades of Gas supplies to the Nepean wing and the new Orchard Ward Block. Gases will be interrupted for up to 2 hours

1. Prior to the shutdown Hoslab is to install and test Back feeds / Portable cylinders in the HDU and Orchard ward.
2. At the time of the shutdown hospital management will check the affected areas to insure that alternative supplies are ready for use.
3. After Hours Supervisor to confirm that the supply can be isolated at Hospital Valve. Access is required to the Vessel compound to bleed oxygen pipe line down.
4. Hoslab is to cut in a new Branch valve into the Medical Oxygen line located in ceiling the space above the entrance to the HDU unit. This valve will feed the proposed Orchard ward extension.
5. Hoslab is to install an isolation valve in the ceiling space above the Theatre suite to allow for isolation of Theatres during refurbishment.
6. The supplies will be re-instated and the joints checked for leaks. The supply will then be turned on at the medical suction vessel and the joints around the new valve will be sprayed with soapy water to check for leaks.
7. At the completion the medical oxygen supply will be re-tested with an Oxygen analyser. A hospital representative (Hospital co-ordinator) will be required to witness this test.
8. Advice will be given to the Hospital staff that the service is satisfactory to use.
9. The Back feed will then be removed from the affected areas.



Thank you for your patience and understanding.

Greg Hall

Chief Executive Officer on behalf of the Executive Management Team.

I:\Business Development\2-Department\Capital Planning\Beleura Business Case\Information memos